

Audio Pack – messages and pre-tones.

The message card fitted in all factory supplied Vigilon Compact Voice alarm panels and DAUs contains an Audio Pack of messages and tones. During commissioning it is possible to re-configure this by selecting alternative centralised and distributed messages and pre tones for Alert, Evacuate, Bomb and Auxiliary 1, 2 and 3 controls.

NUMBER	TYPE OF MESSAGE	VOICE	MESSAGE
1	DAU Test	Male	The voice alarm volumes are being adjusted – there is no need to take any action.
2	Alert (default – Emergency 1)	Female	Your attention please, the fire alarm has been activated in another area, please remain where you are and await further instructions.
3	Evacuate (default – Emergency 2)	Male	Attention please, attention please, this is an emergency. Please leave the building by the nearest available exit. Do not use the lifts or escalators.
4	Bomb (default – Emergency 3)	Female	May I have your attention please, an incident has been reported in the area. As a precaution, please move away from the windows. I repeat, please move away from all windows, further information will follow shortly.
5	Alert (alternative)	Female	May I have your attention please, may I have your attention please, an incident has been reported in the building. While this report is being investigated, please remain at your workplace.
6	Evacuate (alternative)	Male	Ladies and gentlemen, due to unforeseen circumstances we are required to evacuate the building. Please leave the building immediately by the nearest available exit.
7	Gas Carbon Monoxide	Male	May I have your attention please, may I have your attention please, excessive carbon monoxide levels have been detected, please leave the area immediately by the nearest available exit.
8	Gas Fixed Extinguishant	Male	May I have your attention please, may I have your attention please, extinguishant gas release imminent, please evacuate the area immediately by the nearest available exit.
9	Fire alarm test end (default – Auxiliary 1)	Female	Attention please, attention please, this is a test of the fire and voice alarm system, there is no need to take any action.
10	Fire alarm test end (default – Auxiliary 2)	Female	The test of the fire and voice alarm system has now been completed (default – Auxiliary 2)
11	Coded message	Female	Would Mr. Sands please report to reception.
12	Class change	Female	Class change.
13	Gent by Honeywell (advertisement)	Female	Ladies and gentlemen this speech message is produced by Gent by Honeywell's Vigilon Compact Voice alarm system. This product integrates voice alarm functions into an analogue fire alarm system ideal for small to medium sized buildings.
14	Stand down (default – Auxiliary 3)	Female	May I have your attention please, the cause of the alarm has been investigated and the system reset. There is no cause for concern. Thank you.
15	Special tone 1	–	Beep beep beep (950Hz 80ms beep every 420ms)
16	Special tone 2	–	Beep beep beep (950Hz 50ms beep every 80ms)
17	Factory test	–	Frequency sweep (300Hz to 10KHz in 3s)
18	Nursery rhyme 1	Tune	'Boys and Girls Come Out to Play'
19	Nursery rhyme 2	Tune	'Twinkle Twinkle Little Star'

ATTENTION TONE			
Number	Description of tone	Number	Description of tone
1	Nee Naw x 8	6	Pulse
2	Two tone (ding dong)	7	Continuous
3	Four tones – ascending	8	Dong
4	Four tones – descending	9	Chopin
5	Bell	10	'Sleigh Bells'